



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

July 9, 2012
**Subject: Structural Steel
Fabrication and Delivery**
Location: Fort Kent
State PIN: N/A
Amendment No. 2

David Bernhardt
COMMISSIONER

Dear Sir/Ms:

The following question has been received:

Question: Does the fabricator need to be AISC certified to bid this project – per standard specifications?

Response: Yes, per section “504.04 Facility Requirements” in the STATE OF MAINE Department of Transportation Standard Specifications Revision of December 2002.

Consider this information prior to submitting your bid on July 11, 2012.

Sincerely,

For 
George Macdougall
Contracts & Specification Engineer



PRINTED ON RECYCLED PAPER